



TC-13003

District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam (Rural), Deoria

Add.- M2, 1st Construction Division, Bhujauli Colony, Deoria 274001

Test Report

Report No. WTD/006/JUNE(25-26) Date 11.06.2025 Page No. 01/01

Customer Details

Office Name and Address: D.B.R. SENIOR SECONDARY SCHOOL, PAHARPUR, GOTHA RASOOLPUR, DEORIA

Ref Letter No & Date: -

Basic details of sample

District	DEORIA	Block	BAITALPUR
Gram Panchayat	PAHARPUR	Village	GOTHA RASOOLPUR
Habitation	GOTHA RASOOLPUR	Location	PAHARPUR, POSTGOTHA RASOOLPUR, DEORIA
Water Source	R.O.	WQMIS Id	
Quantity of Sample	1000 ml	Date of S.C.	04.06.2025
Receiving Date	04.06.2025	S. Collector	MRS. CHNDRAKANTI RAO
Sample Depositor	MRS. CHNDRAKANTI RAO		
Analysis Start Date	04.06.2025	Analysis Completion Date	10.06.2025

Temperature- 25±3°C


Relative Humidity- 50±15%

Technical Data of Analysis

S. No.	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
3	pH	7.25	6.5	8.5	IS 3025(Part 11): 2022
4	Turbidity (NTU)	0.82	1.0	5.0	IS 3025(Part 10): 2022
5	TDS (mg/l)	80	500	2000	IS 3025(Part 16): 2023
6	Total Alkalinity (mg/l)	46	200	600	IS 3025(Part 23): 2023
7	Total Hardness (mg/l)	24	200	600	IS 3025(Part 21): 2019
8	Calcium (mg/l)	3.2	75	200	IS 3025(Part 40): 2024
9	Magnesium (mg/l)	3.88	30	100	IS 3025(Part 46): 2023
10	Chloride (mg/l)	9.5	250	1000	IS 3025(Part 32): 2019
11	Fluoride (mg/l)	BDL (0.02<0.1)	1.0	1.5	APHA 24 TH Edition 4500-F Method-C (Electrode Method)
12	Nitrate (mg/l)	BDL (0.01<0.1)	45	No relaxation	APHA 24 TH Edition -NO ₃ Method D(UV screening Method)
13	Sulphate (mg/l)	7.07	200	400	APHA 24 TH Edition 4500-SO ₄ Method E(Turbidimetric Method)
14	Iron (mg/l)	0.10	1.0	No relaxation	APHA 24 TH Edition - 3500-Fe Method B(Phenanthroline Method)

#BDL- Below Detection Limit, NA- Not Applicable. ** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

SONAL MISHRA (QUALITY MANAGER)
Reviewed BySONAL MISHRA (QUALITY MANAGER)
Authorized Signatory
Contact No-7905141804

***** End of test report *****

Principal

D.B.R. Senior Secondary School
Paharpur, Deoria

Manager

D.B.R. Senior Secondary School
Paharpur, Deoria